

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7170-0694:190 Page 1 of 2

CATEGORY: Control Unit (High-Rise)

LISTEE: Fire Control Instruments, 301 2nd Avenue, Waltham, MA 02154-1133
Contact: Anthony J. Shalna (781) 471-3000*

DESIGN: Model 7200 high-rise fire alarm control unit. The unit consists of listed Model 7200 control unit (CSFM Listing No. 7165-0694:174) with or without Model FireVac III voice communication system (CSFM Listing No. 6911-0694:129) to form a high rise system. Power-limited; coded, noncoded or marchtime, local; auxiliary, remote station, central station and proprietary signaling system; waterflow, releasing device and sprinkler supervision. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

CAB/B, CAB/C, CAB/D, CAB/A	Cabinet
7200MP/B, 7200MP/A	Mounting Plate
PSU, SPSU	Power Supply Unit
ACU	AC Unit
XFMR	Transformer Assembly
SCU	System Control Unit
QZU	Quad Zone Unit
ALU	Analog Loop Unit
KDU	Keyboard Display Unit
EZU	Eight Zone Unit
ATTE-B	Elec. Actuated Alarm Transmitter
DSU	Dual Signal Unit
ZCU	Zone Coder Unit
EZD	Eight Zone Daughterboard
HRU	High Current Relay Unit
QRU	Quad Relay Unit
PBA	Panel Bus Adapter
EZA	8-Zone Annunciator Board
DIU	Distributed Intelligent Unit
KDU-L	Keyboard Display Unit
FV-7200 ME, FV-7200 SD	Enclosure
SPSU-V	Switching Power Supply
CCU-S, CCU-D	Command Control Unit
SIM-SS, -SD, -A, -P	Switch Input Module
SIB-10R, -10Y	Status Indicator Board
TCU, TCU-R	Telephone Control Unit
AAI	Audio Amplifier Interface
PTT-D, PTT-R	Push To Talk
FCI-MB	Motherboard
FCI-AAM-25	Audio Amplifier Module
FCI-PSM	Power Supply Module

AEU	Audio Evacuation Unit
FVXFMR, FVXFMP	Transformer
ATU	Abort Timer Unit
RDU	Releasing Device Unit
ADC	Audio Driver Card
BAU	Bulk Amplification Unit
PA-120, -250	Amplifiers
IDU	Addressable Interface

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a high rise fire alarm control unit for use with separately listed compatible initiating and indicating devices. Also suitable for use with listee's Model FireVac III Voice Evacuation Unit.

*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 11, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager